



# SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A Unit of Shriram Scientific and Industrial Research Foundation)

## TEST CERTIFICATE

19, University Road, Delhi-110007

Telephone: 91-011-27667267, 27667983, 27667860

Fax: 91-011-27667676, 27667207 E.mail: sridlhi@vsnl.com.

Visit us at <http://www.shriraminstitute.org>

ISO-9001 Certified Institute

000085327

**Issued to :**

DSCL BUILDING PRODUCTS  
PLOT NO. 812, PHASE V  
UDYOG VIHAR  
GURGAON - 122015, HARYANA

**J.O.No.** 406-171-1829  
**Reg.No.** 1129746  
**Date** 05-08-2004  
GC-01 (REV-03)  
**Your Ref.No.** -

**Kind Attn: MR. ASHOK AGGARWAL, MANAGER**

**Sample Particulars :**

One Sample described as Reinforcement 12" marked as B was received.

**Date**

### TEST RESULTS

Tests

Observation

Method Adopted

1) Salt Spray Test (for 20 days)


No sign of rust observed. ASTM-B-117 guidelines

\*\*\*\*\*

D.O.R.: 26.06.2004  
D.O.C.: 04.08.2004

**NOTE**

1. The result listed refer only to the tested sample(s) and applicable parameter(s). Endorsement of products is neither inferred nor implied.
2. Total liability of our Institute is limited to the invoiced amount.
3. Samples will be destroyed one month from the date of issue of test certificate unless otherwise specified.
4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and should not be used in any advertising media without our special permission in writing.
5. In case any reconfirmation of contents of this test certificate is required, please contact our office.

  
**AUTHORISED SIGNATORY**  
 Dy. Director/AD-Chief  
 Sr.Scientist/Scientist





# SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A Unit of Shriram Scientific and Industrial Research Foundation)

## TEST CERTIFICATE

000065756

19, University Road, Delhi-110007

Telephone: 91-011-27667267, 27667983, 27667860

Fax: 91-011-27667676, 27667207 E.mail: sridlhi@vsnl.com.

Visit us at <http://www.shriraminstitute.org>

ISO-9001 Certified Institute

**Issued to :**

DSCL BUILDING PRODUCTS  
PLOT NO. 812, PHASE V  
UDYOG VIHAR  
GURGAON - 122015, HARYANA

J.O.No. 309-171-1097 ms

Reg.No. 1122306

Date 30-10-2003

GC-01 (REV-03)

Your Ref.No. DBP-43

Kind Attn: MR. ASHOK AGGARWAL, MANAGER

**Sample Particulars :**

One sample described as Stainless Steel was received.

Date 11.09.2003

### TEST RESULTS

(guide lines as per IS:9844-1981)

<u>S.No.</u>	<u>Tests</u>	<u>Observed Value</u>
1.	Salt Spray Test (for 20 days)	No sign of blisters, Staining, or corrosion observed.

\*\*\*\*\*

D.O.R.24.09.2003

D.O.C.30.10.2003

**NOTE**

1. The result listed refer only to the tested sample(s) and applicable parameter(s). Endorsement of products is neither inferred nor implied.
2. Total liability of our Institute is limited to the invoiced amount.
3. Samples will be destroyed one month from the date of issue of test certificate unless otherwise specified.
4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and should not be used in any advertising media without our special permission in writing.
5. In case any reconfirmation of contents of this test certificate is required, please contact our office.

AUTHORISED SIGNATORY  
Dy. Director/AD-Chief  
Sr.Scientist/Scientist





# SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A Unit of Shriram Scientific and Industrial Research Foundation)

## TEST CERTIFICATE

19, University Road, Delhi-110007

Telephone: 91-011-27667267,27667983,27667860

Fax: 91-011-27667676,27667207 E-mail: sridlhi@vsnl.com

Visit us at <http://www.shriraminstitute.org>

**ISO-9001 Certified Institute**

000102254

**Issued to :**

FENESTA BUILDING SYSTEMS  
PLOT NO. 812, PHASE-V,  
UDYOG VIHAR, GURGAON  
GURGAON - 122016, HARYANA

**J.O.No.** 503-141-0694  
**Reg.No.** 1137095  
**Date** 06-04-2005  
GC-01 (REV-03)  
**Your Ref.No.** -

**Kind Attn: MR. ASHOK AGARWAL , MANAGER**

**Sample Particulars :**

One sample of " Fenesta UPVC profiles for doors and windows described as Wood grain foiled profile " was received.

**Date** 16.03.2005

### TEST RESULTS

<u>S.No.</u>	<u>Tests</u>	<u>Results</u>	<u>Protocon Adopted</u>
1.	Scratch Resistance Test	Coating is not penetrated to the surface	As per guidelines of IS: 101(Pt5/Sec 2)-1988

\*\*\*\*\*

D.O.R.: 16.03.2005

D.O.C.: 04.04.2005

**AUTHORISED SIGNATORY**  
Dy. Director/AD-Chief  
Sr. Scientist/Scientist  
EMP. CODE NO. (4063 )

**NOTE**

1. The result listed refer only to the tested sample(s) and applicable parameter(s). Endorsement of products is neither inferred nor implied.
2. Total liability of our Institute is limited to the invoiced amount.
3. Samples will be destroyed one month from the date of issue of test certificate unless otherwise specified.
4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and should not be used in any advertising media without our special permission in writing.
5. In case any reconfirmation of contents of this test certificate is required, please contact our office.





# SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A Unit of Shriram Scientific and Industrial Research Foundation)

## TEST CERTIFICATE

19, University Road, Delhi-110007  
Telephone: 91-011-27667267,27667983,27667860  
Fax: 91-011-27667676,27667207 E-mail: sridlhi@vsnl.com  
Visit us at <http://www.shriraminstitute.org>  
**ISO-9001 Certified Institute**

000102252

Issued to :  
FENESTA BUILDING SYSTEMS  
PLOT NO. 812, PHASE-V,  
UDYOG VIHAR, GURGAON  
GURGAON - 122016, HARYANA

J.O.No. 503-141-0692  
Reg.No. 1137095  
Date 06-04-2005  
GC-01 (REV-03)  
Your Ref.No. -

Kind Attn: MR. ASHOK AGARWAL, MANAGER

**Sample Particulars :**

Date 16.03.2005

One sample of " Fenesta UPVC profiles for doors and windows described as Pristine white profile " was received.

### TEST RESULTS

<u>S.No.</u>	<u>Tests</u>	<u>Results</u>	<u>Protocon Adopted</u>
1.	Scratch Resistance Test	Coating is not penetrated to the surface	As per guidelines of IS: 101(Pt5/Sec 2)-1988
2.	Vicat Softening Temperature, °C	83	As per guidelines of ISO 306:1994, Method B

\*\*\*\*\*

D.O.R.: 16.03.2005  
D.O.C.: 04.04.2005

AUTHORISED SIGNATORY  
By: Director/AD-Chief  
Sr.Scientist/Scientist  
EMP. CODE NO. ( 4063 )

- NOTE**
1. The result listed refer only to the tested sample(s) and applicable parameter(s). Endorsement of products is neither inferred nor implied.
  2. Total liability of our Institute is limited to the invoiced amount.
  3. Samples will be destroyed one month from the date of issue of test certificate unless otherwise specified.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and should not be used in any advertising media without our special permission in writing.
  5. In case any reconfirmation of contents of this test certificate is required, please contact our office.





# SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A Unit of Shriram Scientific and Industrial Research Foundation)

## TEST CERTIFICATE

19, University Road, Delhi-110007

Telephone: 91-011-27667267, 27667983, 27667860

Fax: 91-011-27667676, 27667207 E.mail: sridhi@vsnl.com.

Visit us at <http://www.shriraminstitute.org>

ISO-9001 Certified Institute

000082998

**Issued to :**

DSCL BUILDING PRODUCTS

PLOT NO. 812, PHASE V

UDYOG VIHAR

GURGAON - 122015, HARYANA

**J.O.No.**

406-171-1828

**Reg.No.**

1129746

**Date**

05-07-2004

GC-01 (REV-03)

**Your Ref.No.**

-

Kind Attn: MR. ASHOK AGGARWAL, MANAGER

**Sample Particulars :**

One Sample described as Reinforcement 8<sup>mm</sup> marked as A was received.

**Date**

### TEST RESULTS

(Guidelines as per IS:6745-1982)

S.No.    Tests

Observation

1. Average Zinc coating thickness (g/m<sup>2</sup>)

142


\*\*\*\*\*

D.O.R.: 26.06.2004

D.O.C.: 03.07.2004

**NOTE**

1. The result listed refer only to the tested sample(s) and applicable parameter(s). Endorsement of products is neither inferred nor implied.
2. Total liability of our Institute is limited to the invoiced amount.
3. Samples will be destroyed one month from the date of issue of test certificate unless otherwise specified.
4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and should not be used in any advertising media without our special permission in writing.
5. In case any reconfirmation of contents of this test certificate is required, please contact our office.

  
 AUTHORISED SIGNATORY  
 Dy. Director/AD-Chief  
 Sr.Scientist/Scientist

